


City of Fort Saskatchewan
FIRE DEPARTMENT



BUILDING Owners Guide

Required by Alberta Fire Code



Alberta Fire Code Safety Equipment Maintenance Requirements

The City of Fort Saskatchewan Fire Department has prepared this pamphlet listing the fire safety equipment maintenance requirements that are found in Division B of the Alberta Fire Code (AFC) (2019) for all existing buildings. For a complete explanation of the maintenance requirements, the Alberta Fire Code should be consulted.

OWNERS FAILING TO COMPLY WITH MAINTENANCE REQUIREMENTS AS IDENTIFIED IN THE ALBERTA FIRE CODE MAY BE SUBJECT TO FINES OF NOT MORE THAN \$100K AND/OR IMPRISONMENT FOR A TERM NOT EXCEEDING 6 MONTHS, AS PER THE ALBERTA SAFETY CODES ACT SECTION 68(1).

Please contact the Fort Saskatchewan Fire Department with any questions or concerns.



780-998-4858



FSFD@fortsask.ca



10099 - 93 Avenue
Fort Saskatchewan, AB
T8L 1N5





Your responsibilities

as identified in the Alberta Fire Code (2019)

DIVISION C ARTICLE 2.2.1.1.

Unless otherwise specified, the owner or the owner's authorized agent shall be responsible for carrying out the provisions of this Code.

ARTICLE 6.1.1.3.

Before tests, repairs or alterations are made to fire protection installations, including sprinkler, standpipe, fire alarm and detection systems, a procedure of notification shall be established and the procedure shall include notifying the fire department and the building occupants where necessary for safety in the event of a fire emergency.

DIVISION C ARTICLE 2.2.1.2.

A written record shall be kept of all tests, inspections, maintenance or operational procedures for a period of two years after they are made, and the record shall be made available upon request to the Authority Having Jurisdiction.

Definitions

- ▶ **CHECK** means a visual observation to ensure the device or system is in place and is not obviously damaged or obstructed.
- ▶ **INSPECT** means physical examination to determine that the device or system will apparently perform in accordance with its intended function.
- ▶ **TEST** means operation of device or system to ensure that it will perform in accordance with its intended function.
- ▶ **OWNER** means a lessee, a person in charge, a person who has care and control and a person who holds out that the person has the powers and authority of ownership or who, for the time being, exercises the powers and authority of ownership.
- ▶ **AUTHORITY HAVING JURISDICTION (AHJ)** means a safety codes officer in the fire discipline exercising authority pursuant to designation of power and terms of employment in accordance with the Safety Codes Act.
- ▶ **SUPERVISORY STAFF** means those occupants of a building who have some delegated responsibility for the fire safety of other occupants under the fire safety plan.
- ▶ **WATER-BASED FIRE PROTECTION SYSTEMS** Includes sprinkler systems, standpipes, private hydrants, hose systems, water spray fixed systems, foam-water sprinkler systems, foam-water spray systems, and fire pumps.



Check List

- ☐ CHECK
- ☐ INSPECT
- ☐ TEST
- ☐ OWNER
- ☐ AUTHORITY HAVING JURISDICTION (AHJ)
- ☐ SUPERVISORY STAFF
- ☐ WATER-BASED FIRE PROTECTION SYSTEMS

Fire Safety Maintenance Requirements



DAILY	ACF REF#	WEEKLY	ACF REF#
1. Fire Alarm System – CHECK AC power lamp.	6.3.1.2.	1. Fire Pump – CHECK fuel and oil level.	6.4.1.1.
2. Central Alarm and Control Facility – CHECK to ensure that no trouble is indicated.	6.3.1.2.	2. Fire Pump – CHECK water level in reservoirs.	6.4.1.1.
3. Fire Pump Rooms – CHECK temperature during cold weather.	6.4.1.1.	3. Fire Pump – INSPECT and operate.	6.4.1.1.
4. Fire Protection Water Tanks – CHECK tank heating equipment, enclosure and water temperature during heating season in systems without low temperature alarms.	6.4.1.1.	4. Sprinkler System – CHECK that the control valves are open.	6.4.1.1.
5. Exit Signs – CHECK to ensure they are in clean and legible condition.	2.7.3.1	5. Dry Pipe Sprinkler System – CHECK pressure gauge to ensure that air pressure is being maintained.	6.4.1.1.
6. Fire Doors – CHECK doors in fire separation to ensure they remain closed.	2.2.2.4.(1)	6. Fire Protection Water Tanks – CHECK tank heating equipment, enclosure and water temperature during heating season in systems with low temperature alarms.	6.4.1.1.
7. Exit Lights – CHECK to ensure they are illuminated and in good repair.	2.7.3.1.(2)	7. Emergency Generator System – INSPECT, TEST and MAINTAIN as per Table 2 of CAN/CSA C282-05 Emergency Electrical Power Supply For Buildings.	6.5.1.1.*
8. Torches, Regulators and Welding Equipment – CHECK for leakage or defects.	5.2.2.2.		

*These articles require written records (Division C 2.2.1.2.)



8. Hoods, Filters and Ducts in Ventilation Systems – CHECK for accumulation of combustible deposits and clean as required.	2.6.1.3.	6. Portable Fire Extinguishers – INSPECT and sign tag.	6.2.1.1.*
MONTHLY		ACF REF#	
1. Fire Alarm System – TEST system and check all components on emergency power supply including standby power batteries.	6.3.1.2.*	7. Exit Doors – TEST all doors forming part of a means of egress to ensure they are operable.	2.7.2.1.
2. Voice Communication System – TEST the system.	6.3.1.2.*	8. Emergency Lighting Systems – INSPECT and TEST batteries, units and lamps.	6.5.1.6.
3. Water Based Fire Protection Systems – INSPECT all control valve tamper switches.	6.4.1.1.	9. Fire Doors – OPEARATE all doors in fire separations.	2.2.2.4.(3)
4. Fire Protection Water Tanks – INSPECT the water level in tanks not equipped with supervised water level alarms connected to a constantly attended location.	6.4.1.1.	10. Fire Alarm Drills – CONDUCT drills for supervisory staff in day care and health care facilities.	2.8.3.2.
EVERY THREE MONTHS		ACF REF#	
5. Emergency Generator System - INSPECT, TEST and MAINTAIN as per Table 3 of CAN/CSA-C282-05.	6.5.1.1.*	1. All Fire Emergency Systems in High Buildings as defined by Subsection 3.2.6. of the Building Code – TEST.	7.2.1.1.*
		2. Sprinkler Alarm Devices – INSPECT to verify that they are free of physical damage.	6.4.1.1.

*These articles require written records (Division C 2.2.1.2.)

3. Water Based Fire Protection Systems – TEST all system water flow alarm devices.	6.4.1.1.*
4. Water Based Fire Protection Systems – TEST all preaction/deluge valves.	6.4.1.1.*
5. Water Based Fire Protection Systems – TEST all dry pipe valves/quick-opening devices	6.4.1.1.*
6. Fire Department Connections – INSPECT.	6.4.1.1.
7. Main Drain – TEST the main drain of at least one system downstream of a device that has the sole water supply through a backflow preventer and/or pressure reducing valves	6.4.1.1.*
8. Fire Protection Tanks – INSPECT the water level in tanks equipped with supervised water level alarms that are connected to a constantly attended location.	6.4.1.1.

9. CLEAN – hoods, grease removal devices, fans and ducts on commercial equipment used in deep fat cooking, charbroiling or similar cooking operations.	2.6.1.9.*
--	-----------

EVERY SIX MONTHS	ACF REF#
1. Fire Protection Systems – TEST supervisory control valves.	6.4.1.1.*
2. Special Fire Suppression Systems – TEST, INSPECT and MAINTAIN systems as per the appropriate NFPA code.	6.6.1.1.
3. Commercial Cooking Equipment Suppression System – INSPECT and MAINTAIN.	2.6.1.13.*
4. CLEAN hoods, grease removal devices, fans and ducts on commercial cooking equipment.	6.5.1.1.*
5. Emergency Generator System – INSPECT, TEST and MAINTAIN as per Table 4 of CAN/CSA-282-05.	2.8.3.2.*

*These articles require written records (Division C 2.2.1.2.)



6. Fire Alarm Drills – CONDUCT in schools attended by children, three times in both spring and fall terms.	2.8.3.2.*
7. Fire Alarm Drill – CONDUCT for supervisory staff in all high-rise buildings.	6.4.1.1.*
ANNUALLY	ACF REF#
1. Fire Alarm System – CONDUCT a test of the system by qualified personnel acceptable to the AHJ.	6.3.1.2.
2. Voice Communication System – CONDUCT a test of the system by qualified personnel acceptable to the AHJ.	6.3.1.4.

3. Water-Based Fire Protection System – INSPECT, TEST, OPERATE and MAINTAIN components of each system as required by the appropriate NFPA or CAN/ ULC document referenced in the AFC.	6.4.1.1.
4. Fire Pump – CONDUCT a flow test.	6.4.1.1.
5. Water-Based Fire Protection System Riser – TEST the main drain of each riser to determine whether there has been a change in the condition of the water supply piping and control valves.	6.4.1.1.
6. Hydrants – INSPECT and flow test all private hydrants.	6.4.1.1.
7. Standpipe Hose – INSPECT and re-rack.	6.4.1.1.
8. Fire Extinguishers – CONDUCT maintenance procedures by qualified personnel acceptable to the AHJ.	6.2.1.1.
9. Electromagnetic Door Locks – TEST to ensure they work properly.	2.7.2.1.*
10. Sliding Doors – TEST sliding doors that are required to swing on their vertical axis in the direction of egress when pressure is applied.	2.7.2.1.*

*These articles require written records (Division C 2.2.1.2.)



11.Revolving Doors – TEST safety features.	2.7.2.1.*
12.Mechanical Air Conditioning and Ventilation Systems – OPERATE disconnect switches.	2.6.1.6.
13.Fire Dampers and Fire Stop Flaps – INSPECT	2.2.2.4.
14.Sprinkler Heads – INSPECT supply of spare sprinkler heads and replace as required.	6.4.1.1.
15.Emergency Generator System – INSPECT, TEST and MAINTAIN as per Table 5 of CAN/CSA-282 05.	6.5.1.1.*
16.Chimneys, Flues and Flue Pipes – INSPECT.	2.6.1.4.
17.Chimney Spark Arrestors – INSPECT and CLEAN.	2.6.2.3.
18.Fire Alarm Drills – CONDUCT for supervisory staff in buildings with fire alarm systems.	2.8.3.2.*
19.Exhaust and make up air system – TEST and MAINTAIN system initiating devices (i.e. carbon monoxide detector) in enclosed parkades.	2.6.1.6*

EVERY TWO YEARS	ACF REF#
-----------------	----------

- | | |
|--|----------|
| 1. Fire Protection Water Tanks – CHECK steel tanks for corrosion. | 6.4.1.1. |
| 2. Fire Protection Water Tanks – INSPECT all tanks, connected to a non-potable water supply for sediment. | 6.4.1.1. |
| 3. Pressurization Systems – TEST systems in high buildings as defined by Subsection 3.2.6. of the Building Code. | 7.3.2.2. |

EVERY THREE YEARS A	CF REF#
---------------------	---------

- | | |
|--|----------|
| 1. Dry Pipe Sprinkler Systems – TEST the dry pipe valve with the control valve fully open and the quick-opening device, if provided, in service. | 6.4.1.1. |
|--|----------|

EVERY FIVE YEARS	ACF REF#
------------------	----------

- | | |
|---|-----------|
| 1. Sprinkler System – TEST extra-high temperature sprinkler heads as per NPFA document. | 6.4.1.1.* |
| 2. Standpipe System – Flow TEST systems. | 6.4.1.1.* |
| 3. Standpipe System – Hydrostatically TEST system. | 6.4.1.1.* |

*These articles require written records (Division C 2.2.1.2.)



4. Standpipe system – TEST pressure control and pressure reducing valves.	6.4.1.1.*
5. Standpipe System – TEST standpipe hose.	6.4.1.1.*
6. Water Based Fire Protection Systems - TEST all gauges.	6.4.1.1.*

7. Private Hydrant – Flow TEST exposed and underground piping.	6.4.1.1.*
8. Fire Extinguishers – Hydrostatically TEST carbon dioxide and water type extinguishers	6.2.1.1.*
9. Water Based Fire Protection System – INSPECT fire protection water tank for corrosion.	6.4.1.1.
10. Emergency Generator System – INSPECT, TEST, and MAINTAIN as per Table 6 of CAN/CSA-282- 05.	6.5.1.1.

EVERY SIX YEARS A	CF REF#
-------------------	---------

- | | |
|---|----------|
| 1. Fire Alarm System – CONDUCT a test of the system by qualified personnel acceptable to the AHJ. | 6.3.1.2. |
|---|----------|

EVERY TWELVE YEARS	ACF REF#
--------------------	----------

- | | |
|---|-----------|
| 1. Fire Extinguishers – Hydrostatically TEST dry chemical and vaporizing liquid fire extinguishers. | 6.2.1.1.* |
|---|-----------|

EVERY TWENTY YEARS	ACF REF#
--------------------	----------

- | | |
|---|----------|
| 1. Sprinkler System – TEST fast response sprinkler heads. | 6.4.1.1. |
|---|----------|

AS REQUIRED	ACF REF#
-------------	----------

- | | |
|---|----------|
| 1. Fire Department Access – ENSURE streets, yards and private roadways that are provided for fire department access are kept clear. | 2.5.1.3. |
|---|----------|

*These articles require written records (Division C 2.2.1.2.)

2. Dry Pipe Sprinkler Systems – TEST the dry pipe valve with the control valve fully open and the quick-opening device, if provided, in service.	6.4.1.1.	6. Sprinkler System – INSPECT auxiliary drains.	6.4.1.1.
3. Spray Booths – CLEAN residue in walls, ceilings, floors, etc. from spray booths.	5.4.5.2.	7. Fire Doors – CHECK doors in fire separations to ensure they are closed.	2.2.2.4.
4. Means of Egress – CHECK exterior passageways and exterior exit stairs and ensure they are maintained free of snow, ice and obstructions.	2.7.1.7.	8. Dust Producing Operations – CLEAN any combustible dust-producing operations.	5.3.1.2.
5. Smoke Control Equipment – MAINTAIN equipment in a manner that ensures satisfactory operation.	7.3.1.1.	9. Dry-powder Finishing Operations – VACUUM, CLEAN and DUST any dry-powder finishing operations.	5.4.5.2.
		10. Industrial Ovens – INSPECT clean and maintain all industrial ovens and associated ductwork.	5.4.1.2.
		11. CHECK lint traps in laundry equipment.	2.4.1.4



NOTE:

WHENEVER A DEFECT OR DEFICIENCY IS DISCOVERED IN ANY FIRE SAFETY EQUIPMENT AS A RESULT OF THESE MAINTENANCE REQUIREMENTS, CORRECTIVE ACTION MUST BE TAKEN IMMEDIATELY BY THE OWNER OR THE OWNER'S AUTHORIZED AGENT.

Emergency Planning

The building owner is responsible for preparing a fire safety plan, acceptable to the Fire Department, and appointing supervisory staff to carry out the same in all public assembly buildings, care or detention buildings, all buildings equipped with a fire alarm, demolition and construction sites, storage areas, areas where flammable liquids or combustible liquids are stored or handled and areas where hazardous processes or operations occur.

Section 2.8 of the Alberta Fire Code must be referred to in order to get the exact regulations as it applies to your building.

SECTION 2.8

SUBSECTION 2.8.1. GENERAL

2.8.1.1. The requirements of this Section apply to every building containing a Group A (Assemblies) or Group B (Care, Detention, or Treatment) occupancies, and to every building required by the Building Code to have a fire alarm system. 2.8.1.2.(1) Supervisory staff shall be trained in the fire emergency procedures as described in the fire safety plan before they are given any responsibility for fire safety.

SUBSECTION 2.8.2. FIRE SAFETY PLAN

2.8.2.1.(1) A fire safety plan acceptable to the Fire Department which includes the following measures shall be prepared in buildings regulated by Article 2.8.1.1.:

- a) the emergency procedures to be used in case of fire including:
 - i) sounding the fire alarm,
NOTE: If staff have access to fire alarm panels they should only silence the alarm and are not to reset the system.
 - ii) notifying the fire department,
 - iii) instructing occupants on procedures to be follow when the fire alarm sounds,
 - iv) evacuating occupants, including special provision for persons requiring assistance,
- v) confining, controlling and extinguishing the fire.
- b) the appointment and organization of designated supervisory staff to carry out fire safety duties,
- c) the training of supervisory staff and other occupants in their responsibilities for fire safety,
- d) documents, including diagrams, showing the type, location and operations of the building fire emergency systems,
- e) the holding of fire drills,
- f) the control of fire hazards in the building, and

- (g) the inspection and maintenance of building facilities provided for the safety of occupants.2.8.2.1.(2) The fire safety plan shall be reviewed at intervals not greater than 12 months to ensure that it takes account of change in the use and other characteristics of the building.

2.8.2.2.(1) A sufficient number of supervisory staff shall be on duty in care or detention occupancies to perform the tasks outlined in the fire safety plan.

2.8.2.3.(1) In Group A, Division 1 assembly occupancies containing more than 60 occupants, there shall be at least one supervisory staff member on duty in the building to perform the tasks outlined in the fire safety plan whenever the building is open.

2.8.2.4.(1) In buildings within the scope of Subsection 3.2.6. of Division B of the Alberta Building Code, the fire safety plan shall, in addition to the requirements of Sentence 2.8.2.1.(1), include:

- a) the training of supervisory staff in the use of the voice communication system,
- b) the procedures for use of elevators,
- c) the action to be taken by supervisory staff in initiating any smoke control or other fire emergency systems installed in a building in the event of fire until the fire department arrives,
- d) the instructions to the supervisory staff and fire department for the operation of the systems referred to in Clause (c), and
- e) the procedures established to facilitate fire department access to the building and fire location within the building.

2.8.2.5.(1) The fire safety plan shall be kept in the building for reference by the fire department, supervisory staff and other personnel.

2.8.2.5.(2) The fire safety plan for a building within the scope of Subsection 3.2.6. of Division B of the Alberta Building Code 2019 shall be kept at the central alarm and control facility.

2.8.2.6.(1) A copy of the fire emergency procedures and other duties for supervisory staff as stated in the fire safety plan, shall be given to all supervisory staff.

2.8.2.7.(1) At least one copy of the fire emergency procedures shall be prominently posted on each floor area.

IF A FIRE ALARM AND DETECTION SYSTEM, OR PART THEREOF, IS INOPERATIVE FOR MORE THAN 2 HOURS FOR ANY REASON, THE OWNER SHALL NOTIFY THE FIRE DEPARTMENT, AND WHEN DIRECTED, PROVIDE ACCEPTABLE SURVEILLANCE WITHIN THE BUILDING CONTINUOUSLY UNTIL THE FIRE ALARM AND DETECTION SYSTEM IS RESTORED TO OPERATING CONDITION.

Contact

- 📍 10099 - 93 Avenue
Fort Saskatchewan, AB
T8L 1N5
- ☎ 780-998-4858
- ✉ FSFD@fortsask.ca

