

Load Calculation Form

Project Address:
Project Description:

It is at the applicants risk to submit inaccurate or incomplete calculations. Please review additional notes on the backside of this form.

Name / Business: _____

Master No.: _____

Email address: _____

Phone No.: _____

I have verified that the information contained within this document is correct:

Signature

Date

CEC Rule	Principal Dwelling m ²	Secondary m ²
Rule 8-200(2) Minimum ampacity of service feeder conductors from a main supplying two or more dwelling units; <i>and</i>		
(1)(a)(i) is a basic load of 5000 W for the first 90m ² of living area (<i>see rule 8-110</i>); <i>and</i>		
(1)(a)(ii) and additional 1000 W for each 90 m ² or portion thereof in excess of 90m ² ; <i>and</i>		
(1)(a)(iii) any electric space heating loads (<i>section 62</i>); <i>and</i>		
(1)(a)(iii) any AC (<i>Rule 8-106(3)</i>); <i>and</i>		
(1)(a)(iv) single electric range: 6000 W + 40% exceeds 12 kW; <i>and</i>		
(1)(a)(v) electric tankless water heaters or water heaters for steamers, swimming pools, hot tubs, or spas 100%; <i>and</i>		
(1)(a)(vi) electric vehicle charging equipment loads 100%; <i>and</i>		
(1)(a)(vii) additional loads: electric range provided-25%X (>1500 W), or no electric range provided 100% of (>1500 W) up to 6000 W, +25% X (>6000 W); OR		
(1)(b)(i) 100 A, exclusive of basement, is 80m ² or more; or (ii) 60A, exclusive of basement floor area, is less than 80m ²		
Total Calculated Load (W):	W(1)	W(2)
Each Main Breaker, O/C. Type & Size of consumers service conductors	A	AWG
8-200 (2)(a) excluding any electric space-heating and air conditioner loads: 8-202(3)(a)(i) 100% of calculated load of unit with heaviest load; + (3)(a)(ii) 65% of next two units	100% Primary Dwelling (1):	
	65% LWH (2) + (3):	
8-200(2)(a)(b), 8-202(3)(b)(c) Electric space-heating loads " <i>Section 62, subject to Rule 8-106(4)</i> " and 100% air conditioning loads " <i>subject to Rule 8-106(4)</i> "	Electric space heating loads:	
	Air Conditioning loads:	
Total Calculated Load (1), (2) and (W)	Watts	Amps
		Size/Type Service Conductors (AWG)
		Meter Size

OFFICE USE ONLY

Reviewed by:

Signature:

SCO No.:

Date:



CITY OF FORT SASKATCHEWAN

SAFETY CODES

Additional Notes

It is at the applicants risk to submit inaccurate or incomplete calculations.

- 1 square meter = 10.764 square feet
- Applicant must provide accurate m² as calculated from the information in the Building or Development permit for the purpose of CEC Rule 8-110
- CEC Rules 26-600(1) and 26-602 The service panelboard in any dwelling can not be in a closet, bathroom, stairways or undesirable locations. Main service panelboard must be located within the principle dwelling or common area. Branch circuits from a panel board within the principle dwelling/secondary suite must not be located and connected to outlets or electrical equipment in the Garden Suite.
- The size of a consumer's service conductors between the Supply Authority point of attachment and meter base is to be based on the calculated load obtained from Subrule 8-200(1)(a) or (b) and 8-202(3)(a)(i) to (ii); plus 8-202(3)(b) &(c). The main bus of the meter base must comply with Rule 8-200(2)&(1)
- When the calculated demand indicates that an increase of the service is required from a 100A to 200A, you must contact FORTIS at 780-310-9473 to check availability of the increased service size.
- When applying for electrical work in a Secondary Suite a service demand calculation is to be provided by the applicant
- When applying for electrical work where both a Hot Tub and Air Conditioning unit will be on the property a service demand calculation is to be provided by the applicant
- An inspector can request a service demand calculation at any time for any type of project

Questions regarding your calculation form can be submitted to: inspectors@fortsask.ca



CITY OF FORT SASKATCHEWAN
SAFETY CODES